

Project Name :	2020 General Maintenance Contract for Generators				
Item No.	Quantity	Unit	Description	Unit Cost	Total
			Water and Sewer Fund Generators		
2	20	Hours	Technician Hourly Rate for Diagnostic Purposes Directed by City of Tuscaloosa		
3	204	Each	3 Month Inspection-inspect unit and check all fluid levels, check for proper operation of all related components to include but not limited to transfer switch, battery charger, block heater, fuel transfer pump, exhaust system and rain flaps.		
4	10	Each	Run unit online for minimum of two hours and under load to complete online run. THIS WILL NOTE BE A LOAD BANK TEST (See Summary of Work 1.03.D)		
5	21	Each	Yearly Engine Oil Analysis of all Diesel Powered Generators		
6	51	Each	Changing of Oil in Each Generator Once Per Year		
			General Fund Generators		
8	20	Hours	Technician Hourly Rate for Diagnostic Purposes Directed by City of Tuscaloosa		
9	136	Each	3 Month Inspection-inspect unit and check all fluid levels, check for proper operation of all related components to include but not limited to transfer switch, battery charger, block heater, fuel transfer pump, exhaust system and rain flaps.		
10	10	Each	Run unit online for minimum of two hours and under load to complete online run. THIS WILL NOTE BE A LOAD BANK TEST (See Summary of Work 1.03.D)		
11	12	Each	Yearly Engine Oil Analysis of all Diesel Powered Generators		
12	34	Each	Changing of Oil in Each Generator Once Per Year		
			Total Bid		