



BID ADDENDUM NO. 1

August 19, 2020

Bulk Water Treatment Chemicals Bid Number 9045-090120-1

Change #1:

Delete Specifications on pages 8 of original bid for Item # 5 – LIQUID SODIUM PERMANGANATE and replace with the following new Specifications:

ITEM # 5 – LIQUID SODIUM PERMANGANATE

The material shall be an Aqueous Sodium Permanganate Solution that is 20% NaMnO₄ by weight and shall conform to all AWWA Specifications B603-03 for Liquid Sodium Permanganate or the latest revisions thereof.

Liquid Sodium Permanganate is a direct additive used in the treatment of potable water. This material should be certified as suitable for contact with or treatment of drinking water by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals--Health Effects. Evaluation shall be accomplished in accordance with requirements that are no less restrictive than those listed in ANSI/NSF Standard 60. Certification shall be accomplished by a certification organization accredited by the American National Standards Institute.

Actual laboratory analysis of percentage of NaMnO₄ must accompany bills of lading for each shipment.

Estimated annual usage: Fifteen (15) drums

Quantity per delivery: Four (4) 55-gallon drums

Minimum order: Four (4) 55-gallon drums

Packaging: Fifty-five gallons per drum. Condition of drums must be excellent. Unacceptable containers shall be returned to the seller at no cost to the City.



ACCOUNTING & FINANCE

2201 University Blvd. • Tuscaloosa, AL 35401 • Phone 205-248-5170 • Fax 205-349-0197 • City Hall 205-248-5311

TUSCALOOSA.COM

   @TuscaloosaCity



Bidder must sign this addendum and return it with their bid submission in order for their bid to be considered.

Company: _____

Signature: _____

If you have any questions, please contact David Coggins at (205) 248-5186 or dcoggins@tuscaloosa.com

Thank you,

A handwritten signature in blue ink, appearing to read 'David Coggins'.

David Coggins
Purchasing Agent



ACCOUNTING & FINANCE

2201 University Blvd. • Tuscaloosa, AL 35401 • Phone 205-248-5170 • Fax 205-349-0197 • City Hall 205-248-5311

TUSCALOOSA.COM

@TuscaloosaCity